

ABOVEGROUND STORAGE TANK MONTHLY VISUAL INSPECTION FORM

Facility name		Inspection date
Street address	City	ZIP

Use either this form or its equivalent to document monthly visual inspections required by §3-5 of Colorado's Storage tank Regulations. Keep this record at least 12 months. However, it is advisable to keep records indefinitely, since they may be required as part of the compliance review concerning a claim for reimbursement from the Petroleum Storage Tank Fund.

1. Visible leaks on tanks, tank seams, connections, fittings or valves? no yes, If yes, identify tank and describe leak.
Record action taken to remedy the problem and the date corrected.

2. Visible leaks on above-ground piping, pipe seams, connections, fittings, flanges, threaded connections, pumps or valves?
 no yes, If yes, identify and describe leak. Record action taken to remedy the problem and the date corrected.

3. Is overfill prevention equipment in good operating condition? no yes not applicable, If no, identify tank. Record action taken to remedy the problem and the date corrected. *Verify operation of overfill prevention equipment according to the equipment manufacturer's instructions. Verify operation of audible alarm if it can be tested.*

4. If double-walled tank:

A. Is interstice free of liquid? no yes, If no, identify tank and describe leak. Record action taken to remedy the problem and the date corrected.

B. Is interstitial monitoring equipment operating properly? no yes not applicable, If no, identify tank. Record action taken to remedy the problem and the date corrected. *Verify operation of interstitial monitoring equipment according to the equipment manufacturer's instructions.*

5. Secondary containment system free of tank product or other liquids/debris, such as rainwater, snowmelt, dirt, leaves, trash, etc.? no yes not applicable, If no, identify tank. Record action taken to remedy the problem and the date corrected.

6. Are concrete surfaces and ground free of any evidence of new leakage or spillage? no yes, If no, describe. Record action taken to remedy the problem and the date corrected.

Signed	Date
--------	------

**Report suspected or confirmed leaks to the Division of Oil and Public Safety within 24 hours:
(303) 318-8547**